

Diesel Generator

09/15/2016

City of Gallatin

1.0 Introduction

The City of Gallatin is seeking bids for Diesel Generator for the Gallatin Police Department. Bids will be due on September 29th, 2016 at 1:00 pm in a sealed envelope clearly marked: **Diesel Generator**.

1.1 Scope of Work

The City of Gallatin seeks to purchase Diesel Generator Set – 83kW (outdoor).

The City will be responsible for pouring concrete pad.

City will perform all installation.

2.0 Vendor Requirement

Vendor shall deliver f.o.b. to Gallatin, TN.

Vendor to provide complete Specifications on unit with bid

Vendor to provide specification's for concrete pad for generator

3.0 Evaluation of Proposals

The City of Gallatin will award the contract to lowest responsible and responsive bidder meeting specifications, quality, and performance standards pursuant to the Municipal Purchasing Act of 1983. Response will be based on the following factors;

- Completeness of response
- Cost
- Vendor track record, including references
- Quality of service
- Quality of product

4.0 Technical Requirements (Minimum)

Diesel,60Hz, 83kW
Listing-UL 2200
EPA Emission Certification Tier 3,NSPS CI Stationary Emergency
Weather Protective Housing with Critical Muffler
Voltage- 60Hz,120/208,3 Phase,4 W
Alternator-4R9X
Cooling system- Unit mounted Radiator,50c
Skid and Mounting- Skid/Tank
Air Intake- Standard Duty
Controller- DEC3000
Enclosure Type- Weather
Enclosure Material- Steel
Enclosure Silencer- Internal Silencer
Fuel tank Type- Standard
Fuel Run time(Approx.)- 24 hours
Subbase Fuel Tank Capacity- 209 Gallons
Fuel Tank Options- Inner Tank Leak alarm
Starting aids- 1500W,120V
Electrical Acc., installed-Battery, 1/12V, wet
Electrical Acc., installed-Battery Charger, Float, 6A, 1/12V, wet
Electrical Acc., installed- Run Relay
Electrical Acc., installed- DEC 3000 2 input/5 Output Module
Rating, LCB 1 – 80% Rated
Amps, LCB 1 - 300
Trip Type, LCB 1 – Thermal Magnetic, UL/IEC/CSA
Interrupt Rating LCB 1 – 30 kA at 480V
Fuel Lines, installed- Flexible Fuel Lines
Miscellaneous Accy, Installed – Air Cleaner Restriction Ind.
Miscellaneous Accy, Installed – Coolant in Genset
Warranty – Standard one year
Delivery to Job Site / Unload by Others
Startup & Test after City Installation
O & M Manuals
On Site Training (2 hour)

5.0 Contract Award

The City of Gallatin reserves the right to reject any or all proposals and to waive any informality found therein. The City of Gallatin will award a contract based on evaluations described above.

6.0 Question Submissions

Maintenance Supervisor
Attn: Lyndon Satterfield

Telephone: 615-533-8704

7.0 Proposal Submission

BID DUE DATE: September 29th 2016 @1:00 pm

Proposals shall be directed to the attention of:

Finance Department
Attn: J.R.Smith, Jr

132 West Main Street

Gallatin, TN 37066

Telephone: 615-451-5899

TOTAL PRICE: \$ _____

Name of Company: _____

Address: _____

Telephone: _____

Signature: _____

Print Name: _____

Title: _____

Email: _____